



FORM: HVAC-TECH.ENG
PAGE 1 OF 2

TECHNICAL INFORMATION - TYPICAL ANALYSIS

PRODUCT: CANTESCO® GAS LEAK DETECTOR – HVAC SYSTEMS LOW TEMP

APPLICATION: Gas leak detector formulated for HVAC systems including condensing units, service valves and couplings, compressors, evaporators, valves and fittings. Effective to -20°F without freezing. To locate leaks use dauber applicator to apply solution to area being inspected. Absorbent foam dauber spreads compound over entire area being tested, provides lasting bubbles or foam at leak points.

COMPOSITION: Product does not contain mineral oil, vegetable oil, animal oil or fats; any material that will ignite or explode when in contact with liquid or gaseous oxygen; materials that will act as primary skin irritants, skin sensitizers or produce any other dermatosis; ketones, aldehydes, and alcohols as components in the formulation.

TEMP RANGE: -20°F TO 200°F (-29°C TO 93°C)

PACKAGING: Ready to use format available in 8 oz bottles with a 5 ¼” stainless applicator and dauber attached to a wide mouth dauber cap, 1 gallon, 5 gallon and 55 gallon drums.

ITEM	CODE	SIZE	QUANTITY PER BOX
HVAC-08	11145	8 oz bottle	12 bottles per box
HVAC-1G	11395	1 gallon jug	4 jugs per box
HVAC-5G	11400	5 gallon pail	per pail
HVAC-DR	11405	55 gallon drum	per drum

MSDS: An MSDS is available for this product upon request. To receive a copy e-mail us at msds@cantesco.com and request an MSDS for HVAC SYSTEMS LOW TEMP.

PLEASE NOTE: Product use and conditions of use are beyond the control of CANTESCO CORPORATION. Warranty of materials is limited to test results of product performance as detailed in certificates of compliance. Interpretation of test results are the responsibility of the end-user. No other warranties, expressed or implied, are made.

COIL CLEANERS • COIL BRIGHTENERS • SCALE REMOVERS
ICE MACHINE CLEANERS • ELECTRONIC CELL CLEANERS
METAL CLEANERS • DEGREASING SOLVENTS • GAS LEAK DETECTORS



FORM: HVAC-TECH.ENG

PAGE 2 OF 2

TECHNICAL INFORMATION - TYPICAL ANALYSIS

SPECIFICATIONS:

TEST	RESULTS	METHOD
Foreign Matter	clear & free from suspended matter/sediment	MIL-PRF-25567E (sec 4.2.2.1)
Odor	No objectionable odor	ASTM D1292
pH	7.0 (+/-0.5) neutral range	MIL-PRF-25567E (sec 4.2.2.3)
Nonflammability	nonflammable	ASTM D92
Leak Detection	Immediate foaming	MIL-PRF-25567E (sec 4.2.2.5)
Foaming Ability	Initial > 145.0 mm Final > 130.0 mm	ASTM D1173
Freezing Point	-20°F to 200°F (-29°C to 93°C)	ASTM D1177
Residue	Less than 1.00 percent by weight	MIL-PRF-25567E (sec 4.2.2.8)
Corrosion	No corrosion on test panels	MIL-PRF-25567E (sec 4.2.2.9)
Mold Growth	Does not support mold growth	MIL-PRF-25567E (sec 4.2.2.11)
Sulphur	< 000.60 ug/gram	ASTM D-129 / D-516 (B)
Fluoride	< 010.50 ug/gram	ASTM D-808 / D-1179 (B)
Chloride	< 155.00 ug/gram	ASTM D-808 / D-512 (C)
Ammonia	No ammonia	ASTM D1426

Q&A:

For answers on how to use CANTESCO® LEAK DETECTION COMPOUNDS ask for a copy of our LEAK TESTING IN WELDING APPLICATIONS booklet. For a complete product listing request a copy of our HVAC PRODUCTS CATALOG.

To receive a copy of Military specification please contact www.document-center.com. For a copy of ASTM test methods for halogen and chloride content (sulphur, fluoride and chloride) contact the ASTM at www.astm.org. For further links visit us at www.cantesco.com.

PLEASE NOTE: Product use and conditions of use are beyond the control of CANTESCO CORPORATION. Warranty of materials is limited to test results of product performance as detailed in certificates of compliance. Interpretation of test results are the responsibility of the end-user. No other warranties, expressed or implied, are made.

COIL CLEANERS • COIL BRIGHTENERS • SCALE REMOVERS
ICE MACHINE CLEANERS • ELECTRONIC CELL CLEANERS
METAL CLEANERS • DEGREASING SOLVENTS • GAS LEAK DETECTORS